



Electrolux

OPTIONAL HEAT PACKAGE INSTALLATION INSTRUCTIONS FOR USE ON CAL61 AND CAL136 SERIES AIR CONDITIONERS ONLY

- Your Electrolux Model CAL61 or CAL136 Air Conditioner is prewired to easily accept this electric heat accessory.

AIR BOX REMOVAL: (FOR AIR CONDITIONERS CURRENTLY INSTALLED)

CAUTION: MAIN POWER SUPPLY MUST BE TURNED OFF.

- Remove the knobs from the thermostat and selector switch by pulling straight out.
- Remove the return air grilles by placing a flat bladed screw driver or similar tool into the latches. By using a prying motion, the grilles are easily removed. NOTE: Two latches, on either side, must be unhooked.
- Remove four (4) screws holding air box to ceiling template.
- The air box can now be removed.

HEATER INSTALLATION (MAIN POWER SUPPLY MUST BE OFF)

- Install heat package to ceiling template using four (4) sheet metal screws provided. The heater element will align below the discharge air opening and the mounting holes will align with the prepunched holes in the ceiling template.
- Push the electrical plug onto the receptacle at the back of the switch box. Push excess conduit up into return air opening.

AIR BOX INSTALLATION

- A knockout is provided in the wall of the air box which must be removed. The insulation is slit and must be left in place for sealing.
- Slide the air box over the thermostat and switch shafts then over the heater duct.
- Install the four (4) screws through the air box legs and into the ceiling template. (Ref. air conditioner installation instructions.)
- Reinstall the return air grilles and knobs.

TURN POWER ON AND CHECK OPERATION
PER THE AIR CONDITIONER INSTALLATION
AND OPERATION INSTRUCTIONS.

